



Legionnaires Risk Assessment Review

Address: 2 ABC Street, York, YO19 6TD
 Report Completed: 06/01/2015 11:30
 Completed By: Rachel Lightfoot / TouchRight Demo Account

Date of original Risk Assessment: 06/01/2014

Since the original assessment was carried out, has there been a change to the water system or the way it is used by occupants? No

Has there been a change to the use of the building where the system is installed? No

Is there new information available about risks or control measures? No

When testing the temperature of the water in the system, does hot water flow from any outlets at a temperature of below 50C? No

When testing the temperature of water in the system, does cold water flow from any outlets at a temperature of above 20C? No

Are the current tenants and their visitors more susceptible due to their age, health or lifestyle? No

Has there been a case of Legionnaires Disease associated with the system? No

Assessor Signature

Signed by A Smith .