



TOUCHRIGHT
by  **Plentific**

XYZ Lettings (Demo)

1 Sample Street, Sample City S1 2BJ

Email: sample@sampleemail.com

Tel: 01234 567890

Legionnaires Risk Assessment Review



3 ABC Street, London, N1 3EA

Landlord: Jayne Walsh
Report Completed On: 06/01/2015 11:30
Report Completed By: Sample Inspector / XYZ Lettings (Demo)

[View Report Photos](#)



General

Information: This report is to be completed at least once per year.

Date of original Risk Assessment: 06/01/2014

Since the original assessment was carried out, has there been a change to the water system or the way it is used by occupants? No

Has there been a change to the use of the building where the system is installed? No

Is there new information available about risks or control measures? No

When testing the temperature of the water in the system, does hot water flow from any outlets at a temperature of below 50C? No

When testing the temperature of water in the system, does cold water flow from any outlets at a temperature of above 20C? No

Are the current tenants and their visitors more susceptible due to their age, health or lifestyle? No

Has there been a case of Legionnaires Disease associated with the system? No

Assessor Signature

Signed by A Smith .



Please Note: If answers 'yes' to any of the questions above, a new risk assessment should be carried out by a competent person.